



中国国家强制性产品认证证书



证书编号: 2020322313003177

认证委托人名称: CMP PRODUCTS LTD
 认证委托人地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

生产者名称: CMP PRODUCTS LTD
 生产者地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

生产企业名称: CMP PRODUCTS LTD
 企业地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

产品名称: 转接头
 系列、规格、型号: 737/797/787/780/PX780/784/PX784/789/PX789
 标准: GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。产品相关信息详见附件。

发证日期: 2023年04月10日

有效期至: 2025年11月05日

首次发证日期: 2020年11月06日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322313003177

APPLICANT: CMP PRODUCTS LTD
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
MANUFACTURER: CMP PRODUCTS LTD
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
FACTORY: CMP PRODUCTS LTD
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
PRODUCT: Reducers/Adaptors/Unions
SERIES,SPECIFICATION,MODEL: 737/797/787/780/PX780/784/PX784/789/PX789
STANDARDS: GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

Valid from: April 10, 2023

Valid until: November 5, 2025

Date of original certification: November 6, 2020

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn,



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0007241



中国国家强制性产品认证证书



证书编号：2020322313003177

附 件

产品名称：转接头

型号规格：737/797/787/780/PX780/784/PX784/789/PX789

1) 737、797 型产品和螺纹规格之间的关系见下表：

产品规格	公制螺纹规格	NPT 螺纹规格
10	M10	1/8
12	M12	1/4
16	M16	3/8
20	M20	1/2
25	M25	3/4
32	M32	1
40	M40	1-1/4
50	M50	1-1/2
63	M63	2
75	M75	2-1/2
90	M90	3
100	M100	3-1/2
115	M115	4
130	M130	5

产品型号	外螺纹规格范围	内螺纹规格范围
737 转接头	12~130	12~130
737 变径接头	16~130	10~115

批 准：



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号：2020322313003177

附件

797	12~130	10~130
注：该表格内产品材质为金属，当内、外螺纹规格为10、12吋，产品材质只能是不锈钢。		

产品型号	外螺纹规格范围	内螺纹规格范围
737 转接头	20~75	20~90
737 变径接头	20~90	16~75
注：该表格内产品材质为非金属。		

2) 780/PX780/784/PX784/789/PX789 产品螺纹规格范围：M20~M100。

3) 787 产品材质、内外螺纹规格及制造工艺之间的关系见下表：

	Male x Female metric thread size									
	M20xM16	M25xM20	M32xM25	M40xM32	M50xM40	M63xM50	M75xM63	M80xM75	M90xM80	M100xM90
Brass	M/C	M/C	M/C	M/C	M/C	M	M	M	M	M
Aluminium	M	M	M	M	M	M	M	M	M	M
Mild Steel	M/C	M/C	M/C	M/C	M/C	M	M	M	M	M
St. Steel	M/C	M/C	M/C	M/C	M/C	M	M	M	M	M

M - Machined C - Cast

防爆标志： Ex db IIC Gb、 Ex eb IIC Gb、 Ex ta IIIC Da

电气参数： /

相关报告编号： 2022S17402-009767

批 准：



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号：2020322313003177

附 件

使用条件：

特殊（限制）使用条件：

1、产品安全使用特殊条件：

1) 产品工作温度范围：

-60℃~+200℃（780/784/789）、-60℃~+85℃（PX780/PX784/PX789）

-20℃~+60℃（737 非金属版本）。

2) 787 型机加工版本，安装扭矩不应超过下表：

外螺纹规格	安装扭矩 N. m	内螺纹规格	安装扭矩 N. m
M25	53	M25	40
M32	53	M32	40
M40	53	M50	80
M90	166	M75	115
M100	166	M90	115

3) 产品为 Ex 元件，不能单独使用，当合并入 Ex 设备时需附加认证。

2、其他：产品外壳防护等级：IP6X。

批 准：



上海仪器仪表自控系统检验测试所有限公司