



中国国家强制性产品认证证书



证书编号：2020322313003191

认证委托人名称： CMP PRODUCTS LTD
 认证委托人地址： Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 生产者名称： CMP PRODUCTS LTD
 生产者地址： Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 生产企业名称： CMP PRODUCTS LTD
 企业地址： Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 产品名称： 转接头
 系列、规格、型号： 783, 793
 标准： GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021

认证模式：型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求，特发此证。产品相关信息详见附件。

发证日期：2023年04月04日 有效期至：2025年11月08日

首次发证日期：2020年11月09日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准：



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322313003191

APPLICANT: CMP PRODUCTS LTD
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

MANUFACTURER: CMP PRODUCTS LTD
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

FACTORY: CMP PRODUCTS LTD
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

PRODUCT: ADAPTOR
SERIES,SPECIFICATION,MODEL: 783, 793
STANDARDS: GB/T 3836.1-2021、 GB/T 3836.2-2021、 GB/T 3836.3-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

Valid from: April 4, 2023

Valid until: November 8, 2025

Date of original certification: November 9, 2020

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0007158



中国国家强制性产品认证证书



证书编号: 2020322313003191

附件

产品名称: 转接头

型号规格: 783, 793

制造商型号	标准引入口螺纹规格		
	(M)	(F)	(F)
20 793 T	M20×1.5	M20×1.5	M20×1.5
20 793 T	1/2" NPT	1/2" NPT	1/2" NPT
25 793 T	M25×1.5	M25×1.5	M25×1.5
25 793 T	3/4" NPT	3/4" NPT	3/4" NPT
32 793 T	M32×1.5	M32×1.5	M32×1.5
32 793 T	1" NPT	1" NPT	1" NPT
20 783 Y	M20×1.5	M20×1.5	M20×1.5
20 783 Y	1/2" NPT	1/2" NPT	1/2" NPT
25 783 Y	M25×1.5	M25×1.5	M25×1.5
25 783 Y	3/4" NPT	3/4" NPT	3/4" NPT
32 783 Y	M32×1.5	M32×1.5	M32×1.5
32 783 Y	1" NPT	1" NPT	1" NPT

M代表外螺纹形式

F代表内螺纹形式

防爆标志: Ex db IIC Gb、 Ex eb IIC Gb

批准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



SITIiAS
Worldwide Access

证书编号：2020322313003191

附 件

电气参数： /

相关报告编号： 2022S17402-009768

使用条件：

1. 特殊（限制）使用条件：

产品为 Ex 元件，不能单独使用，当合并入 Ex 设备时需附加认证。

2. 使用工作温度范围：

-60°C ~ +200°C

批 准：



上海仪器仪表自控系统检验测试所有限公司