



中国国家强制性产品认证证书



证书编号: 2020322313003430

认证委托人名称: CMP PRODUCTS LTD
 认证委托人地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 生产者名称: CMP PRODUCTS LTD
 生产者地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 生产企业名称: CMP PRODUCTS LTD
 企业地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 产品名称: 电缆引入装置
 系列、规格、型号: A2F100, RA2F100, A2F100HC, RA2F100HC
 标准: GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.8-2021、GB/T 3836.31-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。产品相关信息详见附件。

发证日期: 2023年04月12日

有效期至: 2025年12月01日

首次发证日期: 2020年12月02日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitiias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0009333



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322313003430

APPLICANT: CMP PRODUCTS LTD
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

MANUFACTURER: CMP PRODUCTS LTD
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

FACTORY: CMP PRODUCTS LTD
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

PRODUCT: CABLE GLANDS
SERIES,SPECIFICATION,MODEL: A2F100, RA2F100, A2F100HC, RA2F100HC
STANDARDS: GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.8-2021、GB/T 3836.31-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection
 This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

Valid from:April 12, 2023 **Valid until:**December 1, 2025

Date of original certification:December 2, 2020

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA’s website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0007312



中国国家强制性产品认证证书



证书编号: 2020322313003430

附件

产品名称: 电缆引入装置

型号规格: A2F100、RA2F100、A2F100HC、RA2F100HC

产品规格与引入口螺纹和电缆外部护套直径关系见下表:

产品规格	引入口螺纹			电缆外部护套外径 (mm)	
	标准 公制	标准 NPT	可选 NPT	最小值	最大值
16	M16×1.5	3/8"	-	3.2	8.0
20S16	M20×1.5	1/2"	3/4"	3.2	8.0
20S	M20×1.5	1/2"	3/4"	6.5	11.2
20	M20×1.5	1/2"	3/4"	7.0	13.5
20L	M20×1.5	1/2"	3/4"	8.7	14.0
25	M25×1.5	3/4"	1"	11.5	19.5
25L	M25×1.5	3/4"	1"	14.0	20.0
32	M32×1.5	1"	1(1/4)"	19.0	25.5
32L	M32×1.5	1"	1(1/4)"	20.2	26.3
40	M40×1.5	1(1/4)"	1(1/2)"	25.0	32.2
50S	M50×1.5	1(1/2)"	2"	31.0	38.2
50	M50×1.5	2"	2(1/2)"	35.6	44.0
63S	M63×1.5	2"	2(1/2)"	41.5	49.9
63	M63×1.5	2(1/2)"	3"	48.2	54.9
75S	M75×1.5	2(1/2)"	3"	54.0	61.9
75	M75×1.5	3"	3(1/2)"	61.1	67.9

批准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号：2020322313003430

附 件

产品规格	引入口螺纹			电缆外部护套外径 (mm)	
	标准 公制	标准 NPT	可选 NPT	最小值	最大值
90	M90×2.0	3(1/2)"	4"	66.6	79.9
100	M100×2.0	3(1/2)"	4"	76.0	89.0
115	M115×2.0	4"	5"	86.0	97.9
130	M130×2.0	5"	-	97.0	114.9

防爆标志： Ex eb IIC Gb、 Ex db IIC Gb、 Ex ta IIIC Da、 Ex nR IIC Gc

电气参数： /

相关报告编号： 2023S17402-011123
2020S17402-001815

使用条件： 特殊（限制）使用条件：

1. 安全特殊限制使用条件：产品使用环境温度范围：-60℃~+130℃。
2. 其他：产品外壳防护等级 IP66。

批 准：



上海仪器仪表自控系统检验测试所有限公司