



# 中国国家强制性产品认证证书



证书编号: 2020322313003408

认证委托人名称: CMP PRODUCTS LTD  
 认证委托人地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

生产者名称: CMP PRODUCTS LTD  
 生产者地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

生产企业名称: CMP PRODUCTS LTD  
 企业地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

产品名称: 电缆引入装置  
 系列、规格、型号: TC  
 标准: GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。产品相关信息详见附件。

发证日期: 2023年04月10日

有效期至: 2025年11月23日

首次发证日期: 2020年11月24日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批准:



## 上海仪器仪表自控系统检验测试所有限公司





# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2020322313003408**

**APPLICANT:** CMP PRODUCTS LTD  
**ADDRESS:** Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom  
**MANUFACTURER:** CMP PRODUCTS LTD  
**ADDRESS:** Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom  
**FACTORY:** CMP PRODUCTS LTD  
**ADDRESS:** Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom  
**PRODUCT:** CABLE GLANDS  
**SERIES,SPECIFICATION,MODEL:** TC  
**STANDARDS:** GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

**Type of Certification: Type test + Initial inspection + Surveillance inspection**

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

**Valid from:**April 10, 2023

**Valid until:**November 23, 2025

**Date of original certification:**November 24, 2020

**The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.**

This certificate is available through CNCA’s website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

Guo AiHua



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitiilas.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0007262









# 中国国家强制性产品认证证书



证书编号：2020322313003408

## 附 件

电气参数： /

相关报告编号： 2023S17402-011087  
2020S17402-001814

使用条件： 特殊（限制）使用条件：  
1、安全使用特殊条件：  
1) 产品使用环境温度范围：-60℃~+110℃。  
2) 产品安装时须有效夹紧电缆。  
2、其他：产品外壳防护等级：IP66。

批 准：



## 上海仪器仪表自控系统检验测试所有限公司