







# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2020322313003284**

**APPLICANT:** CMP PRODUCTS LTD  
**ADDRESS:** Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

**MANUFACTURER:** CMP PRODUCTS LTD  
**ADDRESS:** Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

**FACTORY:** CMP PRODUCTS LTD  
**ADDRESS:** Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

**PRODUCT:** CABLE GLANDS  
**SERIES,SPECIFICATION,MODEL:** TMC2  
**STANDARDS:** GB/T 3836.1-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

**Type of Certification: Type test + Initial inspection + Surveillance inspection**

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

**Valid from:**April 12, 2023

**Valid until:**November 19, 2025

**Date of original certification:**November 20, 2020

**The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.**

This certificate is available through CNCA’s website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

Guo AiHua



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0007302





# 中国国家强制性产品认证证书



证书编号：2020322313003284

## 附件

产品名称： 电缆引入装置

型号规格： TMC2

规格型号	电缆外护套直径范围 (mm)	标准 NPT 引入口螺纹	可选 NPT 螺纹
TMC2050S	12.7-19.05	1/2"	3/4"
TMC2050	17.53-25.10	1/2"	3/4"
TMC2075	22.11-30.00	3/4"	1"
TMC2100	25.91-34.85	1"	1(1/4)"
TMC2125S	33.02-41.20	1(1/4)"	1(1/2)"
TMC2125	39.88-48.28	1(1/4)"	1(1/2)"
TMC2150S	41.91-50.82	1(1/2)"	2"
TMC2150	48.50-59.10	1(1/2)"	2"
TMC2200S	48.50-59.10	2"	2(1/2)"
TMC2200	57.70-69.00	2"	2(1/2)"
TMC2250	57.70-69.00	2(1/2)"	3"
TMC2300	66.50-82.70	3"	3(1/2)"
TMC2350	83.30-95.60	3(1/2)"	4"
TMC2400	94.00-108.00	4"	-

除以上所列螺纹规格以外，还可选用以下螺纹规格：

ISO 965-1, ISO965-3 中型 (6g) 外螺纹。

ANSI/ASME B1.20.1-1983 第 8.1 条外螺纹要求的 NPT 螺纹。

批 准：



## 上海仪器仪表自控系统检验测试所有限公司





# 中国国家强制性产品认证证书



证书编号：2020322313003284

## 附 件

BS 31:1940(1979)，表 A。

DIN 40430:1971。

BS 2779：1973 A 类所有外螺纹。

BS 21:1985 第 5.4 条，第 5.2 条系统 A 要求的标准螺纹。

IS07/1:1982，根据 ISO 7/2 6.3 条要求的外螺纹。

ANSI/ASME B1.20.1-1983 第 9 条外螺纹要求的螺纹。

防爆标志： Ex eb IIC Gb、Ex ta IIIC Da

电气参数： /

相关报告编号： 2023S17402-011085  
2020S17402-001812

使用条件： 特殊（限制）使用条件：

1. 安全特殊限制使用条件：产品使用环境温度范围：-60~+110℃。
2. 其他：产品外壳防护等级 IP66。

批 准：



## 上海仪器仪表自控系统检验测试所有限公司