



中国国家强制性产品认证证书



证书编号: 2020322313003283

认证委托人名称: CMP PRODUCTS LTD
 认证委托人地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 生产者名称: CMP PRODUCTS LTD
 生产者地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 生产企业名称: CMP PRODUCTS LTD
 企业地址: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom
 产品名称: 电缆引入装置
 系列、规格、型号: TMC2X
 标准: GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

认证模式: 型式试验+初始工厂检查+获证后监督

上述产品符合 CNCA-C23-01:2019 《强制性产品认证实施规则 防爆电气》的要求, 特发此证。产品相关信息详见附件。

发证日期: 2023年04月12日

有效期至: 2025年11月19日

首次发证日期: 2020年11月20日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitiias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0009320



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322313003283

APPLICANT: CMP PRODUCTS LTD
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

MANUFACTURER: CMP PRODUCTS LTD
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

FACTORY: CMP PRODUCTS LTD
ADDRESS: Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

PRODUCT: CABLE GLANDS
SERIES,SPECIFICATION,MODEL: TMC2X
STANDARDS: GB/T 3836.1-2021、GB/T 3836.2-2021、GB/T 3836.3-2021、GB/T 3836.31-2021

Type of Certification: Type test + Initial inspection + Surveillance inspection
 This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019). Refer to the attachment for detailed information.

Valid from:April 12, 2023 **Valid until:**November 19, 2025

Date of original certification:November 20, 2020

The validity of this certificate is subject to positive result of the periodic surveillance by issuing certification body until the expiry date.

This certificate is available through CNCA’s website: www.cnca.gov.cn



APPROVAL: 
 Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitilas.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844



中国国家强制性产品认证证书



证书编号：2020322313003283

附件

产品名称： 电缆引入装置

型号规格： TMC2X

格兰规格	电缆外护套外径范围 (mm)		最大芯数	典型引入口螺纹尺寸	
	最小值	最大值		NPT	公制
TMC2X**075	12.70	19.05	11	1/2"	M20×1.5
TMC2X**099	17.53	25.10	11	3/4"	M20×1.5
TMC2X**118	22.11	30.00	21	1"	M25×1.5
TMC2X**137	25.91	34.85	38	1(1/4)"	M32×1.5
TMC2X**162	33.02	42.20	59	1(1/2)"	M40×1.5
TMC2X**190	39.88	48.28	59	1(1/2)"	M40×1.5
TMC2X**200	41.91	50.82	89	2"	M50×1.5
TMC2X**233	48.50	59.10	89	2"	M50×1.5
TMC2X**233	48.50	59.10	115	2(1/2)"	M63×1.5
TMC2X**272	57.70	69.00	115	2(1/2)"	M63×1.5
TMC2X**272	57.70	69.00	140	3"	M75×1.5
TMC2X**325	66.50	82.70	140	3(1/2)"	M90×1.5
TMC2X**376	80.30	95.60	140	4"	M100×1.5
TMC2X**425	94.00	108.00	200	4"	M115×1.5
TMC2X-M50**1621RA*/S	33.02	41.15	59	-	M50×1.5
TMC2X-M63**233/2001RA*	41.91	50.80	89	-	M63×1.5

注：1) TMC2X**，**代表 NPT 或公制螺纹尺寸，具体见上表。

批准：



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号：2020322313003283

附件

2) TMC2X-M50**1621RA*/S 和 TMC2X-M63**233/2001RA*:

**电缆引入装置本体材质选项，代码为 SS 代表不锈钢、NB 代表镀镍黄铜。

*为配套螺母和垫片材质选项，代码为 4 代表不锈钢，5 代表镀镍黄铜。

除以上所列螺纹规格以外，还可选用满足 ANSI/ASME B1.20.1-1983 第 8.1 条外螺纹要求的 NPT 螺纹。

防爆标志： Ex eb IIC Gb、Ex db IIC Gb、Ex ta IIIC Da

电气参数： /

相关报告编号： 2023S17402-011083
2020S17402-001811

使用条件： 特殊（限制）使用条件：
1. 产品安全使用特殊条件：
1) 产品使用环境温度范围：-60℃~+85℃。
2) 产品隔爆面不能维修。
2. 其他：产品外壳防护等级：IP66。

批 准：



上海仪器仪表自控系统检验测试所有限公司