

UK Type Examination Certificate CML 21UKEX1238X Issue 1

United Kingdom Conformity Assessment

- 1 Product or Protective System Intended for use in Potentially Explosive Atmospheres UKSI 2016:1107 (as amended) – Schedule 3A, Part 1
- 2 Equipment **Type 737 & 797 Ranges of Adaptors & Reducers and 747, 757 & 767 Ranges of Stopping Plugs**
- 3 Manufacturer **CMP Products Ltd**
- 4 Address **Unit 36 Nelson Way
Nelson Park East,
Cramlington
NE23 1WH
UK**

5 The equipment is specified in the description of this certificate and the documents to which it refers.

6 Eurofins E&E CML Limited, Newport Business Park, New Port Road, Ellesmere Port, CH65 4LZ, United Kingdom, Approved Body Number 2503, in accordance with Regulation 43 of the Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016, UKSI 2016:1107 (as amended), certifies that this equipment has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment intended for use in potentially explosive atmospheres given in Schedule 1 of the Regulations.

The examination and test results are recorded in the confidential reports listed in Section 12.

7 If an 'X' suffix appears after the certificate number, it indicates that the equipment is subject to specific conditions of use (affecting correct installation or safe use). These are specified in Section 14.

8 This UK Type Examination certificate relates only to the design and construction of the specified equipment. Further requirements of the Regulations apply to the manufacturing process and supply of the product. These are not covered by this certificate.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the confidential report, has been demonstrated through compliance with the following documents:

EN IEC 60079-0:2018

EN IEC 60079-7:2015+A1:2018

EN 60079-1:2014

EN 60079-31:2014

10 The equipment shall be marked with the following:



I M2 Ex db I Mb and/or Ex eb I Mb



II 2 G Ex eb IIC Gb

II 2 G Ex db IIC Gb and/or Ex eb IIC Gb

II 1 D Ex ta IIIC Da

II 1 D Ex ta IIIC Da





CML 21UKEX1238X
Issue 1

11 Description

The Type 737 & 797 Ranges of Adaptors & Reducers and 747, 757 & 767 Ranges of Stopping Plugs are designed for explosive atmospheres, supplied in metallic and non-metallic (excluding 797 range) material options.

The Adaptor and Reducer product ranges convert an existing cable entry thread to another type and/or size. They comprise a hexagonal or cylindrical body – with flats – threaded from both ends providing the change required. These can be manufactured with equal threads or a combination of various sizes and types, unless otherwise stated.

- 737 Adaptor – Comprises a male (M) entry thread, adapting to a female (F) thread of the same size or larger, and limited to a change of two 'standard' thread sizes, e.g. M16 x M25.
- 737 Reducer – Comprises a male (M) entry thread, reducing to a female (F) thread, smaller and not limited by a specific number of thread sizes, e.g. M130 (M) x M10 (F) being acceptable.
- 797 Adaptor/Reducer – Comprises M/M or F/F threads only and limited to a change of two 'standard' thread sizes; with the exception of F/F thread options, where a change of three 'standard' thread sizes is allowed for M20 (F) x M10 (F) only.

Stopping Plug product ranges provide a means of blanking unused cable entries, giving Ex protection.

- 747 Stopping Plug – Comprises a cylindrical body with an external male thread and hexagonal, or square drive, recess or protrusion.
 - Non-tamperproof – allen key hexagonal, or square drive, recess only accessible outside the enclosure
 - Tamperproof – allen key hexagonal, or square drive, recess only accessible inside the enclosure
- 757 Stopping Plug – Comprises a hexagonal head and cylindrical body with an external male thread.
- 767 Stopping Plug – Comprises a cylindrical body with an external male thread and domed head with allen key hexagonal, or square drive, recess.

Materials of manufacture

Metallic:

- Brass; aluminium; stainless steel; mild steel.

Non-Metallic:

- Glass reinforced flame-retardant nylon (Excluded from Group I applications).

All brass manufactured component parts can be optionally nickel-plated. All mild steel manufactured components can be optionally zinc plated.



CML 21UKEX1238X
Issue 1

Design Options

- The male entry component can be fitted with an O-ring seal, which locates on the mating face with its associated enclosure. This option having the product type prefixed with the letter 'R'. Applicable to 737, 757, 767, and 797 (M/M only) product ranges.
- Alternative entry component thread forms; Metric, ET (conduit), PG, BSPP, BSPT, ISO, NPT, and NPSM. Refer to R12922A for thread specifications.
- Intermediate thread sizes permitted, e.g. M28.

Thread and Size Designations:

Table 1 details the size reference and thread designation of the thread options covered. Table 2 details the products and their approved thread size ranges:

Table 1

737 / 747 / 757 / 767 / 797							
Size Reference and Recognised Equivalent Threads							
Size Ref.	Metric	NPT	NPSM	BSPP	BSPT	PG DIN	E.T.
10	M10	1/8	1/8	1/8	1/8	-	3/8
12	M12	1/4	1/4	1/4	1/4	PG7	1/2
16	M16	3/8	3/8	3/8	3/8	PG9	5/8
20	M20	1/2	1/2	1/2	1/2	PG11 PG13.5	3/4
25	M25	3/4	3/4	3/4	3/4	PG16 PG21	1
32	M32	1	1	1	1	-	1-1/4
40	M40	1-1/4	1-1/4	1-1/4	1-1/4	PG29	1-1/2
50	M50	1-1/2	1-1/2	1-1/2	1-1/2	PG36	2
63	M63	2	2	2	2	PG42	2-1/2
75	M75	2-1/2	2-1/2	2-1/2	2-1/2	PG48	3
90	M90	3	3	3	3	-	3-1/2
100	M100	3-1/2	3-1/2	3-1/2	3-1/2	-	4
115	M115	4	4	4	4	-	-
130	M130	5	5	5	5	-	-

NOTE: Metric entry threads of all model ranges may be manufactured with a thread pitch between 0.7 mm and 2.0 mm, with 1.5 mm as standard, with the exception of Size 10 which is only permitted with a 1.0 mm thread pitch.



CML 21UKEX1238X
Issue 1

Table 2

Product Range	Metallic*	
	Male Thread (Size Ref.)	Female Thread (Size Ref.)
737 Adaptor	12 to 130	12 to 130
737 Reducer	16 to 130	10 to 115
797	12 to 130	10 to 130
747 / 757 / 767	12 to 130	-
* Stainless Steel only, when any thread size 10 or 12 is required		
Product Range	Non-metallic*	
	Male Thread (Size Ref.)	Female Thread (Size Ref.)
737 Adaptor	20 to 75	20 to 90
737 Reducer	20 to 90	16 to 75
747 / 757 / 767	20 to 100	-
* Excluded from Group I applications		

Variation 1

This variation introduces the following modifications:

- i. Introduction of a square socket (recessed) and a square plug (protrusion) on the 747 Stopping plugs and 767 Stopping plugs.
- ii. Modification to the specific conditions of use

12 Certificate history and evaluation reports

Issue	Date	Associated report	Notes
0	04 May 2021	R12735B/00	Issue of Prime Certificate
1	02 Feb 2024	R16280A/00	Introduction of Variaton 1

Note: Drawings that describe the equipment are listed in the Annex.

13 Conditions of Manufacture

The following conditions are required of the manufacturing process for compliance with the certification.

- i. Where the product incorporates certified parts or safety critical components, the manufacturer of the product defined on this certificate shall continually monitor these parts/components for any modifications introduced by the manufacturer(s) of these constituent parts. If the manufacturer of any constituent part introduces any changes which affect the compliance of the certified product that is the subject of this certificate, the manufacturer is required to have this certificate updated.
- ii. Non-metallic and aluminium adaptors, reducers and stopping plugs shall not bear any Group I marking.



CML 21UKEX1238X
Issue 1

14 Specific Conditions of Use

The following conditions relate to safe installation and/or use of the equipment.

- i. The interfaces between a male thread of an adaptor/reducer and an associated enclosure, between a female thread of an adaptor/reducer and a cable entry device, and between a stopping plug and an associated enclosure cannot be defined. Therefore, it is the installer's responsibility to ensure that the appropriate ingress protection level is maintained at these interfaces.
- ii. Non-metallic adaptors, reducers and stopping plugs shall not be used in enclosures where the temperature, at the point of mounting, is outside the range of -20°C to +60°C.
- iii. The installer shall refer to the manufacturer's instructions for the action necessary regarding the electrostatic risk associated with non-metallic adaptors, reducers and stopping plugs.
- iv. Any cable gland used with the non-metallic adaptors and reducers shall be non-metallic.
- v. The adaptors, reducers and stopping plugs sizes 10 & 12 have been tested to a mechanical impact of 7 J and therefore, when used in Group I applications, shall only be installed where the risk of mechanical impact is low.

Certificate Annex

Certificate Number CML 21UKEX1238X
Equipment Type 737 & 797 Ranges of Adaptors & Reducers and 747,
757 & 767 Ranges of Stopping Plugs
Manufacturer CMP Products Ltd



The following documents describe the equipment defined in this certificate:

Issue 0

For all drawings, refer to attached certificate CML 18ATEX1320X.

Issue 1

Drawing No	Sheets	Rev	Approved date	Title
GA2372	1 to 2	02	09 Feb 2024	ADAPTORS, REDUCERS, AND STOPPING PLUGS