

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20121005-E256367B  
**Report Reference** E256367-20060106  
**Issue Date** 2012-OCTOBER-05

**Issued to:** **CMP PRODUCTS**  
GLASSHOUSE ST  
ST PETERS  
NEWCASTLE-UPON-TYNE  
NE6 1BS UNITED KINGDOM

**This is to certify that  
representative samples of**


CABLE FITTINGS FOR USE IN ZONE CLASSIFIED  
HAZARDOUS LOCATIONS  
MARINE SHIPBOARD CABLE FITTINGS FOR USE IN  
ZONE CLASSIFIED HAZARDOUS LOCATIONS  
See Addendum Page

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** UL 50, Enclosures for Electrical Equipment,  
UL 514B, Conduit, Tubing, and Cable Fittings,  
UL 2225, Cables and Cable Fittings for Use in Hazardous  
(Classified) Locations,  
EN 50014:1992,  
EN 50018:1994,  
EN 60529:1992.

**Additional Information:** See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's  
Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle:  with the  
word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category  
name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)



# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20121005-E256367B  
**Report Reference** E256367-20060106  
**Issue Date** 2012-OCTOBER-05

, This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements

Type Marine Shipboard cable sealing fittings for use only with copper, bronze, aluminum or stainless steel grounding braid cable. For use in Class I, Zone 1, AEx d IIC Hazardous Areas. For vertical or horizontal mounting in hazardous locations. For use only with manufacturer's "Denso" Type 2122 sealing compound. Conduit sizes -1/2 in. to 3 in. NPT and M16 to M75 inclusive.  
20/16PX2KX, 20SPX2KX, 20PX2KX, 25PX2KX, 25SPX2KX, 32PX2KX, 40PX2KX, 50SPX2KX, 50PX2KX, 63SPX2KX, 63PX2KX, 75SPX2KX, 75PX2KX, 90PX2KX.



William R. Carney, Director, North American Certification Programs  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

